

## DECLARATION OF PERFORMANCE No. PM/CFDM-V/01/20/3

1.	Unique identification code of the product-type	CFDM-V	
2.	Products	Dampers – Fire dampers	
	Intended use	Fire safety. To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.	
	Technical documentation  – product information, instruction for installation and maintenance, safety information	Technical specifications TPM 118/16	
3.	Manufacturer	MANDÍK, a.s. Dobříšská 550, 26724 Hostomice, Czech Republic ID 26718405, tel. +420 311 706 706 mandik@mandik.cz, www.mandik.com	
5.			
6.	Harmonised standard	EN 15650:2010	
	Notified body	Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek	
	Output documents of the notified body	Certificate of Constancy of Performance No. 1391-CPR-2020/0129/O1 Assessment Report of Performance of Construction Product No. P-1391-CPR-2020/0129	

7a.	a. Declared performances – fire resistance classification			
	Essential characteristics in accordance with EN 15650:2010, art. 4.1.1			
Fire separating construction, location of the damper Solid wall construction – damper in the wall		Installation type, installation system  Mortar or gypsum 1]  Mineral wool with fire protection	Performance — class of fire resistance  As per purchase order EI 120 (ve i↔o) S, or	
- 100	) mm min. wall thickness	coating and cement lime plate 1]	EI 90 ( $v_e i \leftrightarrow o$ ) S, or EI 60 ( $v_e i \leftrightarrow o$ ) S.	
		Mineral wool boards with fire protection coating <sup>1]</sup>	As per purchase order EI 90 ( $v_e i \leftrightarrow o$ ) S, or EI 60 ( $v_e i \leftrightarrow o$ ) S.	
wall o	um plasterboard construction nper in the wall ) mm min. wall thickness	Mortar or gypsum <sup>1]</sup> Mineral wool with fire protection coating and cement lime plate <sup>1]</sup>	As per purchase order EI 120 ( $v_e$ i $\leftrightarrow$ 0) S, or EI 90 ( $v_e$ i $\leftrightarrow$ 0) S, or EI 60 ( $v_e$ i $\leftrightarrow$ 0) S.	
		Mineral wool boards with fire protection coating <sup>1]</sup>	As per purchase order EI 90 ( $v_e i \leftrightarrow o$ ) S, or EI 60 ( $v_e i \leftrightarrow o$ ) S.	
– dar – ceil – n – n	ceiling construction mper in the ceiling ing thickness nin. 110 mm for concrete nin. 125 mm for aerated oncrete	Mortar or gypsum <sup>1]</sup> Mineral wool plates with fire protection coating <sup>1]</sup>	As per fire resistance class shown on the purchase order EI 90 ( $h_0$ i $\leftrightarrow$ 0) S, or EI 60 ( $h_0$ i $\leftrightarrow$ 0) S.	

<sup>1]</sup> Refer to <u>Technical documentation</u> for the details of the installation type / installation system.

7b.	Declared performances – other essential characteristics		
Essential characteristics		Requirements (provisions of the harmonised standard EN 15650:2010)	Performance (lever or class) / Compliance with the requirements
Nominal activation conditions/sensitivity:		4.2.1.2	Conforms
– sensing element load bearing capacity		4.2.1.2.2	Conforms
<ul> <li>sensing element response temperature</li> </ul>		4.2.1.2.3	Conforms
Response delay (response time):  – closure time		4.2.1.3	Conforms
Operational reliability:  – cycling		4.3.1, a)	0 cycles – conforms
Durability of response delay:		4.2.1.2.2	Conforms
<ul> <li>sensing element response to</li> </ul>		4.2.1.2.3	
temperature and load bearing capacity			
Dura	bility of operational reliability:	4.3.3.2	NPD – no performance
– оре	ening and closing cycle tests		determined

7c.	Declared performances – other characteristics			
Characteristics		Technical standard	Performance (lever or class) / Compliance with the requirements	
Resis	tance against corrosion	EN 15650:2010, art. 4.2.2 EN 15650:2010, Annexe B	Conforms	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

In Hostomice, 18 Septemer 2020