

Number	20-000006-PR01 (NW-K05-09-en-01)
Owner	Soudal N.V. Everdongenlaan 18-20 2300 Turnhout Belgium
Product	Single-component polyurethane foam
Designation	Shipping name: Soudafoam PURE B1
Details	Manufacturer Soudal N.V., 2300 - Turnhout; Material Polyurethane (PUR)
Special features	-/-

Result

Determination of water vapor transmission permeability according to EN ISO 12572, Set A



Water vapour
resistance factor $\mu_{0/50} = 21$
Diffusion equivalent
air layer thickness $S_{d0/50} = 1.5 \text{ m}^*$

*) for a material thickness of 69 mm

Basis *)

ift-Richtlinie MO-01/1:2007-01

EN ISO 12572:2016-08

*) and corresponding national versions
(e.g. DIN EN)

Test report: 20-000006-PR01 PB-K05-09-en-01

Representation



Validity

There is no time limit.

When using this document the up-to-dateness of above basis and the conformity of the product have to be observed.

The data and results given relate solely to the tested/described specimen. This test/evaluation does not allow any statement to be made on further characteristics of the present structure regarding performance and quality.

Notes on publication


The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

ift Rosenheim

29.06.2020



Michael Freinberger, Dipl.-Ing. (FH)
Head of Testing Department
Material Testing



Jennifer Seyfang, Dipl.-Ing. (FH)
Operating Testing Officer
Material Testing

Identity-Check



www.ift-rosenheim.de/ift-geprueft
ID: C88-13B4A