

UL INTERNATIONAL (UK) LTD Wonersh House, Building C, The Guildway, Old Portsmouth Road, Guildford. GU3 1LR. United Kingdom.





designated according to Article 29 of the Regulation (EU) No 305/2011 and member of EOTA (European Organisation for Technical Assessment, www.eota.eu)

# European Technical Assessment

ETA 14/0037 of 06/02/2015

Technical Assessment Body issuing the ETA and designated according to Article 29 of the Regulation (EU) No 305/2011: UL International (UK) Ltd

Trade name of the construction product Gr

Graft FR Acrylic

Product family to which the construction product belongs

Fire Stopping and Sealing Product:

Penetration Seals

Manufacturer Polyseam AS

Ravneveien 7

Linnestad Næringsområde N-3174 Revetal, Norway http://www.polyseam.com

Manufacturing plant(s) Polyseam Ltd

Shaw Park Silver Street

Huddersfield. West Yorkshire

HD5 9AF, UK

**This European Technical Assessment** 

contains

38 pages including 1 Annex which forms an

integral part of this assessment.

This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of

ETAG 026-2, edition 2011, used as European Assessment Document (EAD).

This version replaces ETA 14/0037 issued on 21/02/2014

Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and should be identified as such.

Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may be made, with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.

#### **Table of Contents**

I.	SPECII	FIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT	3
1	Te	echnical description of the product	3
2		pecification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter AD): ETAG 026-2	
3	Pe	erformance of the product and references to the methods used for its assessment	5
4		SSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO SEED ASSESSMENT AND VERIFICATION OF CONSTANCE OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO	
5	Te	echnical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD	6
6	Iss	sued on:	7
ANN	IEX A – F	Resistance to Fire Classification – Graft FR Acrylic	8
Α	.1	Rigid wall constructions according to 1.2.1 with wall thickness of minimum 150 mm	8
	A.1.1	Single side penetration seal with cables	8
	A.1.2	Double side penetration seal with cables	9
	A.1.3	Single side penetration seal with metallic (and composite) pipes	. 10
	A.1.4	Single side penetration seal with metallic (and composite) pipes	. 12
	A.1.5	Double side penetration seal with metallic pipes	. 14
Α	.2	Flexible wall constructions according to 1.2.1 with wall thickness of minimum 100 mm	. 16
	A.2.1	Double side penetration seal with cables	. 16
	A.2.2	Double side penetration seal with metallic pipes	. 17
	A.2.3	Double side penetration seal with composite pipes	. 20
	A.2.4	Double side penetration seal with metallic (and composite) pipes	. 21
	A.2.5	Double side penetration seal with plastic pipes	. 23
Α	3	Rigid floor constructions according to 1.2.1 with floor thickness of minimum 150 mm	. 24
	A.3.1	Single side penetration seal with cables	. 24
	A.3.2	Double side penetration seal with cables	. 26
	A.3.3	Single side penetration seal with metallic pipes	. 27
	A.3.4	Single side penetration seal with composite pipes	. 31
	A.3.5	Double side penetration seal with metallic pipes	. 32
	A.3.6	Double side penetration seal with metallic pipes	. 33
	A.3.7	Double side penetration seal with metallic pipes	. 36
	A.3.8	Double side penetration seal with plastic pipes	. 38

#### I. SPECIFIC PARTS OF THE EUROPEAN TECHNICAL ASSESSMENT

#### 1 Technical description of the product

- 1) Graft FR Acrylic is a sealant used to form a penetration seal around metallic pipes, plastic pipes, composite pipes and electrical cables to reinstate the fire resistance performance of wall and floor constructions, where they have been provided with apertures for the penetration of services.
- 2) The Graft FR Acrylic is supplied in liquid form contained within 310 & 380 ml cartridges and 600 ml foil packs. The sealant is gunned into the aperture in the separating element/elements and around the service or services, to a specified depth utilising mineral fibre insulation backing material.
- Graft FR Acrylic contains no carcinogenic substances or mutagenic substances, flame retardants or antimicrobiological agents.
- 4) Polyseam AS submitted a written declaration that Graft FR Acrylic does not contain substances which have to be classified as dangerous according to Directive 67/548/EEC and Regulation (EC) No 1272/2008 and listed in the "Indicative list on dangerous substances" of the EGDS taking into account the installation conditions of the construction product and the release scenarios resulting from there. An emission report has also been provided.
  - In addition to the specific clauses relating to dangerous substances contained in this European technical Assessment, there may be other requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.
- 5) The use catagory of Graft FR Acrylic in relation to BWR 3 (Hygiene, health and environment) is IA1, S/W3

#### 2 Specification of the intended uses of the product in accordance with the applicable European Assessment Document (Hereinafter EAD): ETAG 026-2

Detailed information and data is given in Annex A.

- 1) The intended use of system Graft FR Acrylic is to reinstate the fire resistance performance of flexible wall constructions, rigid wall constructions and rigid floor constructions where they are penetrated by various metal pipe services with and without combustible insulation, plastic pipes, composite pipes and electrical cables.
- 2) The specific elements of construction that the system Graft FR Acrylic may be used to provide a penetration seal in, are as follows:

a. Flexible walls: The wall must have a minimum thickness of 100 mm and comprise steel studs or timber studs\* lined on both faces with minimum 2 layers

of 12.5 mm thick boards.

b. Rigid walls: The wall must have a minimum thickness of 150 mm and comprise

concrete, aerated concrete or masonry, with a minimum density of

 $650 \text{ kg/m}^3$ .

c. Rigid floors: The floor must have a minimum thickness of 150 mm and comprise

aerated concrete or concrete with a minimum density of 650 kg/m<sup>3</sup>.

\* no part of the penetration seal may be closer than 100 mm to a stud, the cavity must be closed between the penetration seal and the stud, and minimum 100 mm of insulation of class A1 or A2 according to EN 13501-1 must be provided within the cavity between the penetration seal and the stud.

The supporting construction must be classified in accordance with EN 13501-2 for the required fire resistance period.

- 3) The system Graft FR Acrylic may be used to provide a penetration seal with specific single insulated metal pipes, uninsulated metal pipes, plastic pipes, composite pipes and with specific electrical cables, single or in a bundle (for details see Annex A).
- 4) Apertures in the separating element shall be maximum 300 x 300 mm or 100 x 1000 mm. The annular space/gap around the services shall be infilled with mineral fibre insulation backing material and Graft FR Acrylic sealant. Blank seals up to 300 x 300 mm are permitted. For full details, see Annex A.
- 5) Pipes shall be supported at maximum 350 mm away from both faces of the wall constructions and from the upper face of floor constructions.
- 6) The provisions made in this European Technical Approval are based on an assumed working life of the Graft FR Acrylic of 30 years, provided that the conditions laid down in sections 4.2/5.1/5.2 for the packaging/transport/ storage/installation/use/repair are met. The indications given on the working life cannot be interpreted as a guarantee given by the producer, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.
- 7) Type Z<sub>2</sub>: Intended for uses in internal conditions with humidity lower than 85 % RH excluding temperatures below 0°C, without exposure to rain or UV.

#### 3 Performance of the product and references to the methods used for its assessment

Product-type: Sealant		Intended use: Penetration Seal				
Basic requirement for construction work	Basic Requ	uirement	Performance			
	BWR 1 Mechanical re	sistance and stabilit	у			
-	Nor	ne	Not relevant			
	BWR 2 Safety	in case of fire				
EN 13501-1	Reaction	n to fire	Class D-s1, d1			
EN 13501-2	Resistano	ce to fire	Annex A			
	BWR 3 Hygiene, hea	lth and environment				
EN 1026:2000	Air permeability (r	naterial property)	No performance determined			
ETAG 026-2, Annex C	Water permeability	(material property)	No performance determined			
Declaration of manufacturer	Release of dange	rous substances	Use categories: IA1, S/W3  Declaration of manufacturer			
	BWR 4 Sa	fety in use				
EOTA TR 001:2003	Mechanical resist	ance and stability	No performance determined			
EOTA TR 001:2003	Resistance to im	pact/movement	No performance determined			
EOTA TR 001:2003	Adhe	sion	No performance determined			
	BWR 5 Protection	on against noise				
EN 10140-2/ EN ISO 717-1	Airborne sou	nd insulation	No performance determined			
	BWR 6 Energy econor	ny and heat retention	n			
EN 12664, EN 12667 or EN 12939	Thermal p	roperties	No performance determined			
EN ISO 12572 EN 12086	Water vapour	No performance determined				
General aspects relating to fitness for use						
EOTA TR 024:2009, clause 3.1.11 & 3.1.12	Durability and	serviceability	Z <sub>2</sub>			
	BWR 7 Sustainable us	e of natural resource	es			
-			No performance determined			

# 4 ASSESSMENT AND VERIFICATION OF CONSTANCY OF PERFORMANCE (HEREINAFTER AVCP) SYSTEM APPLIED, WITH REFERENCE TO ITS LEGAL BASE

According to the decision 1999/454/EC – Commission Decision of date 22nd June 1999 on on the procedure for attesting the conformity of construction products pursuant to Article 20(2) of Council Directive 89/106/EEC as regards fire stopping, fire sealing and fire protective products, published in the Official Journal of the European Union (OJEU) L178/52 of 14/07/1999, see http://eur-lex.europa.eu/JOIndex.do) of the European Commission<sup>1</sup>, as amended, the system(s) of assessment and verification of constancy of performance (see Annex V to Regulation (EU) No 305/2011) given in the following table(s) applies (apply).

Product(s)	Intended use(s)	Level(s) or class(es)	System(s)
Fire stopping and Fire Sealing Products	For fire compartmentation and/or fire protection or fire performance	Any	1

## 5 <u>Technical details necessary for the implementation of the AVCP system, as provided for in the applicable EAD</u>

Tasks of the manufacturer:

Factory production control

The manufacturer shall exercise permanent internal control of production. All the elements, requirements and provisions adopted by the manufacturer shall be documented in a systematic manner in the form of written policies and procedures, including records of results performed. This production control system shall ensure that the product is in conformity with this European technical Assessment.

The manufacturer may only use initial / raw / constituent materials stated in the technical documentation of this European Technical Assessment.

The factory production control shall be in accordance with the Control Plan of 8<sup>th</sup> April 2013 relating to the European technical assessment ETA 14/0037 issued on 06/02/2015 which is part of the technical documentation of this European technical approval. The "Control Plan" is laid down in the context of the factory production control system operated by the manufacturer and deposited at UL International (UK) Ltd.

The results of factory production control shall be recorded and evaluated in accordance with the provisions of the Control Plan.

<sup>&</sup>lt;sup>1</sup> Official Journal of the European Communities L178/52 of 14/7/1999

#### Other tasks of the manufacturer

#### Additional information

The manufacturer shall provide a technical data sheet and an installation instruction with the following minimum information:

- (a) Technical data sheet:
  - Field of application:
  - Building elements for which the linear joint seal or penetration seal is suitable, type and properties of the building elements like minimum thickness, density, and - in case of lightweight constructions – the construction requirements.
  - Limits in size, minimum thickness etc. of the joint or penetration seal
  - Construction of the linear joint seal or penetration seal including the necessary components and additional products (e.g. backfilling material) with clear indication whether they are generic or specific.
  - Services which the penetration seal is suitable, type and properties of the services like material, diameter, thickness etc. in case of pipes including insulation materials; necessary/allowed supports/fixings (e.g. cable trays)
- (b) Installation instruction:
  - Steps to be followed
  - Procedure in case of retrofitting
  - Stipulations on maintenance, repair and replacement

#### 6 Issued on:

6<sup>th</sup> February 2015

Report by:

Reviewed by:

C. Johnson Staff Engineer

**Building and Life Safety Technologies** 

C. W. Miles
Business Manager – Europe & Latin America
Building and Life Safety Technologies


For and on behalf of UL International (UK) Ltd.

## ANNEX A – Resistance to Fire Classification – Graft FR Acrylic

#### A.1 Rigid wall constructions according to 1.2.1 with wall thickness of minimum 150 mm

#### A.1.1 Single side penetration seal with cables

**Penetration Seal:** Cables (single) fitted at centrally within the aperture, with Graft FR Acrylic to either side of the wall (or at any position in between), backed with stone wool insulation 35kg/m<sup>3</sup> or 'Graft Mineral Fibre BIO'. Minimum separation between cables and the edge of the seal of 7 mm.




#### A.1.1.1

Services	Sealant depth	Backing	Maximum seal size	Classification
Single electrical cables up to 21 mm Ø	25 mm	48 mm deep Graft Mineral Fibre BIO	87 mm Ø	E 240, El 90
Blank seals  Electric cables up to 21 mm diameter, single.	Mineral	48 mm Graft Mineral	300 x 300 mm	E 240, EI 60
Blank seals  Electric cables up to 21 mm diameter, single.	25 mm	Fibre BIO insulation	35 x 35 mm / 36 mm Ø	E 240, El 120

#### A.1.2 Double side penetration seal with cables

**Penetration Seal:** Cables fitted with Graft FR Acrylic to both sides of the wall, backed with stone wool insulation 35kg/m<sup>3</sup>. Maximum seal size of 300 x 300 mm and minimum separation between cables and the edge of the seal of 10 mm.




#### A.1.2.1

Services	Sealant	Backing	Insulation	Classification
	depth			
Blank seals				EI 240
Electric cables up to 21 mm diameter, single or in a bundle.	15 mm	25 mm Stone wool		E 240 EI 120
Electric cables 22-80 mm diameter, single or in a bundle.		35 kg/m <sup>3</sup>		E 120 EI 60
Blank seals	25 mm	48 mm	None	El 240
Electric cables up to 80 mm diameter, single or in a bundle.		Graft Mineral		E 240 EI 60
Telecoms cables up to 21 mm diameter, single or in a bundle up to 100 mm diameter		Fibre BIO		EI 240

#### A.1.3 Single side penetration seal with metallic (and composite) pipes

**Penetration Seal:** LI (Local Interrupted) of minimum length stated below or CI (Continuous Interrupted) insulated metallic and composite pipes (single) fitted central within the aperture, with 15 mm deep Graft FR Acrylic to either side of the wall (or at any position between), backed with 20 mm deep 40 kg/m<sup>3</sup> stone wool insulation\*.




#### A.1.3.1

Services	Seal width around pipe	Insulation	Classification
Copper pipe up to 54 mm diameter/0.9-14.2 mm wall	8-9 mm	1000 mm length 20 mm Stone wool	E 240 C/U, EI 180 C/U
Copper pipe up to 12 mm diameter/0.9-5 mm wall	8 mm	insulation 80 kg/m <sup>3</sup>	EI 240 C/U
Alupex composite pipe 75 mm diameter/7.5 mm wall	30 mm	25 mm Graft Mineral Fibre BIO insulation, 600 mm long (min.)	EI 120 C/U

Services	Seal width	Insulation	Classification
Mild or stainless steel pipe	around pipe		
40 mm diameter/1.5-14.2 mm wall*		1000 mm length of 20 mm Stone wool insulation 80 kg/m <sup>3</sup>	EI 240 C/U
40 mm diameter/1.5-14.2 mm wall*			
50 mm diameter/1.7-14.2 mm wall*			
60 mm diameter/1.9-14.2 mm wall*			
75 mm diameter/2.2-14.2 mm wall*			
90 mm diameter/2.5-14.2 mm wall*			
100 mm diameter/2.7-14.2 mm wall*	6-18 mm	1000 mm length of 30	
115 mm diameter/3-14.2 mm wall*		mm Stone wool insulation 80 kg/m <sup>3</sup>	E 180, EI 90 C/U
140 mm diameter/3.5-14.2 mm wall*			
165 mm diameter/ 3.9-14.2 mm wall*			
180 mm diameter/ 4.2-14.2 mm wall*			
200 mm diameter/ 4.6-14.2 mm wall*			
219 mm diameter/ 5.0-14.2 mm wall*			


<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes

#### Pipe diameter vs Wall thickness



#### A.1.4 Single side penetration seal with metallic (and composite) pipes

**Penetration Seal:** LI (Local Interrupted) of minimum length stated below or CI (Continuous Interrupted) insulated metallic and composite pipes (single) fitted central within the aperture, with 25 mm deep Graft FR Acrylic to either side of the wall (or at any position between), backed with 25 mm deep 40 kg/m<sup>3</sup> stone wool insulation\*.




#### A.1.4.1

Services	Maximum Seal size	Insulation	Classification
Copper pipe up to 54 mm diameter/0.9-14.2 mm wall		1000 mm length 20 mm Stone wool	
Copper pipe up to 12 mm diameter/0.9-5 mm wall	300 x 300	insulation 80 kg/m <sup>3</sup>	E 240 C/U, EI 60 C/U
Alupex composite pipe 75 mm diameter/7.5 mm wall	mm	25 mm Graft Mineral Fibre BIO insulation, 600 mm long (min.)	

Services	Maximum seal	Insulation	Classification
Mild or stainless steel pipe	size		
40 mm diameter/1.5-14.2 mm wall*		1000 mm length of 20 mm Stone wool insulation 80 kg/m <sup>3</sup>	
40 mm diameter/1.5-14.2 mm wall*			
50 mm diameter/1.7-14.2 mm wall*			
60 mm diameter/1.9-14.2 mm wall*			
75 mm diameter/2.2-14.2 mm wall*			
90 mm diameter/2.5-14.2 mm wall*			
100 mm diameter/2.7-14.2 mm wall*	300 x 300 mm	1000 mm length of 30	E 240 C/U, EI 60 C/U
115 mm diameter/3-14.2 mm wall*		mm Stone wool insulation 80 kg/m <sup>3</sup>	
140 mm diameter/3.5-14.2 mm wall*		J.	
165 mm diameter/ 3.9-14.2 mm wall*			
180 mm diameter/ 4.2-14.2 mm wall*			
200 mm diameter/ 4.6-14.2 mm wall*			
219 mm diameter/ 5.0-14.2 mm wall*			


<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes

#### Pipe diameter vs Wall thickness



#### A.1.5 Double side penetration seal with metallic pipes


**Penetration Seal:** 1000 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes (single) fitted central within the aperture, with 15 mm deep Graft FR Acrylic to both sides of the), backed with 20 or 30 mm deep  $40 \text{ kg/m}^3$  stone wool insulation.



#### A.1.5.1

Services	Maximum seal	Insulation	Classification
Mild or stainless steel pipe	size		
40 mm diameter/1.5-14.2 mm wall*		20 mm Stone wool insulation 80 kg/m <sup>3</sup>	EI 240 C/U
40 mm diameter/1.5-14.2 mm wall*			
50 mm diameter/1.7-14.2 mm wall*			
60 mm diameter/1.9-14.2 mm wall*			
75 mm diameter/2.2-14.2 mm wall*			
90 mm diameter/2.5-14.2 mm wall*			
100 mm diameter/2.7-14.2 mm wall*	300 x 300 mm	30 mm Stone wool	5 340 51 430 6/11
115 mm diameter/3-14.2 mm wall*		insulation 80 kg/m <sup>3</sup>	E 240, EI 120 C/U
140 mm diameter/3.5-14.2 mm wall*			
165 mm diameter/ 3.9-14.2 mm wall*			
180 mm diameter/ 4.2-14.2 mm wall*			
200 mm diameter/ 4.6-14.2 mm wall*			
219 mm diameter/ 5.0-14.2 mm wall*			


<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes



#### A.2 Flexible wall constructions according to 1.2.1 with wall thickness of minimum 100 mm

#### A.2.1 Double side penetration seal with cables

**Penetration Seal:** Cables (single or bundles up to 100 mm Ø) fitted at any position within the aperture, with Graft FR Acrylic to both sides of the wall, backed with stone wool insulation 40kg/m³, 140 kg/m³ or 'Graft Mineral Fibre BIO'.




#### A.2.1.1

Services	Sealant depth	Backing	Maximum aperture	Classification
None (blank)	12.5 mm	Stone wool 20 mm deep 35-140 kg/m <sup>3</sup>		El 120
Electrical cables up to 21 mm Ø, single or in bundles up to 100 mm Ø		Stone wool 20 mm deep 40 kg/m <sup>3</sup>		El 120
Electrical cables up to 80 mm Ø, single or in bundles up to 100 mm Ø	25 mm	25 mm Graft Mineral Fibre BIO	300 x 300 mm*	E 120, El 60
Telecommunication cables up to 21 mm Ø single or in bundles up to 100 mm Ø		Stone wool 20 mm deep 40 kg/m <sup>3</sup>		E1120
Single 'E cable' - 1 x 185 mm <sup>2</sup> core HD603.3 electrical cable with PVC insulation, PVC sheath and 23-27 mm diameter	12.5 mm	Stone wool 20 mm deep/140 kg/m <sup>3</sup>		E 120, El 60

<sup>\*</sup> Or 30 mm wide x 3000 mm high for cables up to 21 mm  $\emptyset$ 

#### A.2.2 Double side penetration seal with metallic pipes

**Penetration Seal:** CS (Continuous Sustained) insulated metallic pipes (single) fitted central within the aperture, with Graft FR Acrylic to both sides of the wall, backed with stone wool insulation or 'Graft Mineral Fibre BIO', 300 x 300 mm maximum seal size.




#### A.2.2.1

Services	Sealant	Backing	Insulation	Classification
Mild or stainless steel pipe	depth			
22 mm diameter/3-10 mm wall	25 mm	Stone wool 25 mm deep 35 kg/m <sup>3</sup>	None	EI 120 C/C
40 mm diameter/1-14.2 mm wall	12.5 mm	20 mm Stone wool 40 kg/m <sup>3</sup>		EI 120 C/C
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.3-14.2 mm wall*				
60 mm diameter/1.6-14.2 mm wall*				
75 mm diameter/2-14.2 mm wall*		25 mm	13 -19 mm Kaiflex ST insulation	
90 mm diameter/2.4-14.2 mm wall*	25 mm	Graft Mineral	31 msdiation	E 120 C/C EI 60 C/C
100 mm diameter/2.7-14.2 mm wall*		Fibre BIO		Li do c/ c
115 mm diameter/3.1-14.2 mm wall*				
140 mm diameter/3.8-14.2 mm wall*				
165 mm diameter/ 4.5-14.2 mm wall*				

<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes


#### Pipe diameter vs Wall thickness



Services	Sealant	Backing	Insulation	Classification
Copper pipe	depth			
12 mm diameter/1 mm wall			9 mm Kaiflex ST	EI 120 C/C
		25 mm	insulation	Li 120 C/C
12-54 mm diameter/1-1.2 mm wall	25 mm	Graft	9-13 mm Kaiflex ST	E 120, EI 60 C/C
	23 111111	Mineral	insulation	L 120, LI 00 C/C
12-54 mm diameter/1-1.2 mm wall		Fibre BIO	13-25 mm Kaiflex	EI 60 C/C
			ST insulation	LI 00 C/C
Gerberit Mepla MLC (PE-Xb/Aluminiun	n/PE-HD pipe	e)*		
16 mm diameter/2.25 mm wall			9 mm Kaiflex ST	EI 120 C/C
			insulation	Li 120 C/C
16 mm diameter/2.25 mm wall				
20 mm diameter/2.5 mm wall				
26 mm diameter/3 mm wall		25 mm		
32 mm diameter/3 mm wall	25 mm	Graft Mineral	9-25 mm Kaiflex ST	51.50.0/0
40 mm diameter/3.5 mm wall		Fibre BIO	insulation	EI 60 C/C
50 mm diameter/4 mm wall				
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall				

#### A.2.3 Double side penetration seal with composite pipes

**Penetration Seal:** CI (Continuous Interrupted) or CS (Continuous Sustained) insulated composite pipes (single) fitted central within the aperture, with Graft FR Acrylic to both sides of the wall, minimum 10 mm seal width around service, maximum seal size 300 x 300 mm, backed with stonewool.




#### A.2.3.1

Services	Sealant	Backing	Insulation	Classification
Gerberit Mepla MLC (PE-	depth		(minimums)	
Xb/Aluminium/PE-HD pipe)*				
16 mm diameter/2.25 mm wall				
20 mm diameter/2.5 mm wall				
26 mm diameter/3 mm wall				
32 mm diameter/3 mm wall	12.5 mm	12.5 mm	20 mm stonewool 80 kg/m <sup>3</sup> , 500 mm	51.420.676
40 mm diameter/3.5 mm wall		stonewool 40 kg/m³	length from both sides of the seal	EI 120 C/C
50 mm diameter/4 mm wall			sides of the sear	
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall				

#### A.2.4 Double side penetration seal with metallic (and composite) pipes

**Penetration Seal:** LI (Local Interrupted) of minimum length stated below or CI (Continuous Interrupted) insulated metallic pipes and composite (single) fitted central within the aperture, with Graft FR Acrylic to both sides of the wall, min. 10 mm seal width around service, backed with stone wool insulation or 'Graft Mineral Fibre BIO'.




#### A.2.4.1

Services	Sealant Backing depth		Insulation	Classification
Ma	ıximum ape	rture size 300	x 300 mm	
Copper pipe up to 54 mm diameter/1-14.2 mm wall	20 mm Stone wool 40 kg/m <sup>3</sup>		500 mm length of 20 mm stone woo,l 80 kg/m <sup>3</sup>	EI 120 C/U
Alupex composite pipe 75 mm diameter/7.5 mm wall	12.5 mm	20 mm Stone wool 140 kg/m <sup>3</sup>	600 mm length of 25 mm Graft Mineral Fibre BIO	EI 60 C/U


Services	Sealant	Backing	Insulation	Classification		
Mild or stainless steel pipe	depth					
Maximum aperture size 300 x 300 mm						
40 mm diameter/1-14.2 mm wall			500 mm length of 20 mm stone wool 80 kg/m³	EI 120 C/U		
40 mm diameter/1-14.2 mm wall*						
50 mm diameter/1.2-14.2 mm wall*						
60 mm diameter/1.4-14.2 mm wall*	42.5	20mm				
75 mm diameter/1.7-14.2 mm wall*	12.5 mm	Stone wool 40 kg/m <sup>3</sup>	500 mm length of 30 mm stone wool 80 kg/m <sup>3</sup>	5 430 5100 0/H		
90 mm diameter/2-14.2 mm wall*		_		E 120, EI 90 C/U		
100 mm diameter/2.2-14.2 mm wall*						
115 mm diameter/2.5-14.2 mm wall*						
140 mm diameter/3-14.2 mm wall*						
165 mm diameter/3.5-14.2 mm wall*						
180 mm diameter/3.8-14.2 mm wall*	12.5	20mm	500 mm length of	5 4 3 0 5 1 0 0 C/**		
200 mm diameter/4.2-14.2 mm wall*	12.5 mm	Stone wool 40 kg/m <sup>3</sup>	30 mm stone wool 80 kg/m <sup>3</sup>	E 120, EI 90 C/U		
219 mm diameter/4.5-14.2 mm wall*						

<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes



#### A.2.5 Double side penetration seal with plastic pipes

**Penetration Seal:** Combustible pipes (single) fitted central within the aperture, with Graft FR Acrylic to both sides of the wall, 10 mm seal width around PVC pipes and 29 mm around PP pipes. No backing material is required but PE foam may be utilised.



#### A.2.5.1


Services	Sealant depth	Backing	Aperture Ø	Classification
PVC-U pipe according to EN 1329-1, EN 1452-1 and EN	12.5 mm			EI 45 U/C, EI 45 C/C
1453-1, PVC-C according to EN 1566-1* 32 mm Ø/1.7 mm wall	25 mm	None required	52 mm	EI 90 U/C, EI 90 C/C
PP pipe according to EN 1451-1 32 mm Ø/2 mm wall	25 mm		90 mm	

<sup>\*</sup> In Germany the pipes have additionally to comply with DIN 19531-10

#### A.3 Rigid floor constructions according to 1.2.1 with floor thickness of minimum 150 mm

#### A.3.1 Single side penetration seal with cables


**Penetration Seal:** Cables (single) fitted centrally within circular apertures or min. 30 mm from the edges of rectilinear apertures, with Graft FR Acrylic to either side of the floor (or at any position in between), backed with 'Graft Mineral Fibre BIO'.



#### A.3.1.1

Services	Sealant depth	Backing	Aperture	Classification
Single electrical cables up to 21 mm Ø	25 mm	Graft Mineral Fibre BIO 25 mm deep	82 mm Ø or max. 100 x 1000 mm	E 120, El 60

**Penetration Seal:** Cables fitted with Graft FR Acrylic to the top side of the floor, backed with stone wool insulation  $35 \text{kg/m}^3$  or Graft Mineral Fibre BIO. Maximum seal size of 300 x 300 mm and minimum separation between cables and the edge of the seal of 10 mm.




#### A.3.1.2

Services	Sealant depth	Backing	Insulation	Classification
	15 mm	20 mm Stone wool 35 kg/m <sup>3</sup>		E 90 EI 60
Blank seals		25 mm Stone wool 35 kg/m <sup>3</sup>	Naca	El 120
			None	EI 240
Electric cables up to 21 mm diameter, single.	25 mm	48 mm		E 120 EI 90
23-27 mm diameter, 1 mm × 185 mm <sup>2</sup> core, PVC sheath and insulation electrical cable, single		Mineral Fibre BIO		El 240

#### A.3.2 Double side penetration seal with cables

**Penetration Seal:** Cables fitted circular apertures or min. 7 mm from the edges of rectilinear apertures, with Graft FR Acrylic to both sides of the floor, backed with stone wool insulation 35kg/m<sup>3</sup>.




#### A.3.2.1

Services	Sealant depth	Backing	Aperture	Classification
Blank seals				EI 240
Electric cables up to 21 mm diameter, single or in a bundle.		25 mm	200 200	El 120
Electric cables 22-50 mm diameter, single or in a bundle.	15 mm	Stone wool 35 kg/m <sup>3</sup>	300 x 300 mm	E 120 EI 90
Electric cables 51-80 mm diameter, single or in a bundle.		33 Kg/111		E 120 EI 60

#### A.3.3 Single side penetration seal with metallic pipes

**Penetration Seal:** 1000 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes (single) fitted central within the aperture, with 15 or 25 mm deep Graft FR Acrylic to either side of the floor (or at any position between), backed with 40 kg/m<sup>3</sup> stone wool insulation or Graft Mineral Fibre BIO.



#### A.3.3.1


Services	Max. seal size	Insulation	Sealant depth	Classification										
Copper pipe up to 54 mm diameter/0.9-14.2 mm wall	10 mm	20	1E mm	E 240 C/U, EI 180 C/U										
Copper pipe up to 12 mm diameter/0.9-5 mm wall	around pipe			ound pipe Stone wool		EI 240 C/U								
Copper pipe up to 54 mm diameter/0.9-14.2 mm wall	Up to 100 x 1000 mm	insulation 80 kg/m <sup>3</sup>	25 mm	EI 120 C/U										
Copper pipe up to 54 mm diameter/0.9-14.2 mm wall		20 mm	15 mm	E 90 C/U, EI 60 C/U										
Copper pipe up to 12 mm diameter/0.9-5 mm wall	300 x 300 mm											Stone wool insulation	13 111111	2 30 6/ 0/, 21 00 6/ 0
Copper pipe up to 54 mm diameter/0.9-14.2 mm wall		80 kg/m <sup>3</sup>	25 mm	EI 120 C/U										


Services	Max. Seal Size	Insulation	Sealant	Classification
Mild or stainless steel pipe			Depth	
40 mm diameter/1-14.2 mm wall		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		EI 240 C/U
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*	10 mm width		15 mm	
100 mm diameter/2.2-14.2 mm wall*	around pipe	30 mm Stone wool	13 11111	
115 mm diameter/2.5-14.2 mm wall*		insulation 80		E 240, EI 90 C/U
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*				
40 mm diameter/1-14.2 mm wall*		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*	Up to 100 x			
100 mm diameter/2.2-14.2 mm wall*	1000 mm	30 mm Stone	25 mm	E120, EI 90 C/U
115 mm diameter/2.5-14.2 mm wall*		wool insulation 80		
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*				

<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes

Services	Max. Seal Size	Insulation	Sealant	Classification
Mild or stainless steel pipe			Depth	
40 mm diameter/1-14.2 mm wall		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		
40 mm diameter/1-14.2 mm wall*				
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*			15 mm	E 90 C/U, EI 60 C/U
100 mm diameter/2.2-14.2 mm wall*		30 mm Stone wool	13 111111	2 30 0, 0, 21 00 0, 0
115 mm diameter/2.5-14.2 mm wall*		insulation 80		
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*	300 x 300 mm			
40 mm diameter/1-14.2 mm wall*		20 mm Stone wool insulation 80 kg/m <sup>3</sup>		
50 mm diameter/1.2-14.2 mm wall*				
60 mm diameter/1.4-14.2 mm wall*				
75 mm diameter/1.7-14.2 mm wall*				
90 mm diameter/2-14.2 mm wall*				
100 mm diameter/2.2-14.2 mm wall*		30 mm Stone	25 mm	E120, EI 90 C/U
115 mm diameter/2.5-14.2 mm wall*		wool insulation 80		
140 mm diameter/3-14.2 mm wall*		kg/m <sup>3</sup>		
165 mm diameter/3.5-14.2 mm wall*				
180 mm diameter/3.8-14.2 mm wall*				
200 mm diameter/4.2-14.2 mm wall*				
219 mm diameter/4.5-14.2 mm wall*				


<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes





#### A.3.4 Single side penetration seal with composite pipes

**Penetration Seal:** CI (Continuous Interrupted) insulated composite pipes (single) fitted central within the aperture, with Graft FR Acrylic, minimum 10 mm seal width around service and maximum 300 x 300 mm seal, backed with 'Graft Mineral Fibre BIO'.




#### A.3.4.1

Services	Sealant	Backing	Insulation	Classification
Gerberit Mepla MLC (PE-	depth		(minimums)	
Xb/Aluminium/PE-HD pipe)*				
16 mm diameter/2.25 mm wall				
20 mm diameter/2.5 mm wall				
26 mm diameter/3 mm wall				
32 mm diameter/3 mm wall	25 mm	48 mm Graft	20 mm stonewool 80 kg/m³, 500 mm	
40 mm diameter/3.5 mm wall	]	Mineral	length from both	EI 240 C/C
50 mm diameter/4 mm wall		Fibre BIO	sides of the seal	
63 mm diameter/4.5 mm wall				
75 mm diameter/4.7 mm wall				

#### A.3.5 Double side penetration seal with metallic pipes

**Penetration Seal:** Non-insulated metallic pipes (single) fitted central within the aperture, with 25 mm deep Graft FR Acrylic to both sides of the floor, backed with 25 mm deep 140 kg/m<sup>3</sup> stone wool insulation.




#### A.3.5.1

Services	Max. Seal Size	Insulation	Backing	Classification
Copper pipe 54 mm diameter/2-14.2 mm wall	300 x 300	None	25 mm deep 140 kg/m <sup>3</sup> stone wool	E 120 C/U, EI 20 C/U
Mild steel pipe 16 mm diameter/1.5-7.5 mm wall	mm			EI 240 C/U
Mild steel pipe 16 mm diameter/1.5-7.5 mm wall	Up to 100 x 1000 mm	None	Graft Mineral Fibre BIO 25 mm deep	EI 120 C/U

#### A.3.6 Double side penetration seal with metallic pipes

**Penetration Seal:** CS (Continuous Sustained) insulated metallic pipes (single) fitted central within the aperture, with Graft FR Acrylic to both sides of the wall, maximum 300 x 300 mm seal width around service, backed with stone wool insulation or 'Graft Mineral Fibre BIO'.




#### A.3.6.1

Services	Sealant	Backing	Insulation	Classification
Mild or stainless steel pipe	depth			
40 mm diameter/1-14.2 mm wall	25 mm	20 mm Stone wool 40 kg/m <sup>3</sup>		EI 180
40 mm diameter/1-14.2 mm wall*  50 mm diameter/1.3-14.2 mm wall*	25 mm			
60 mm diameter/1.6-14.2 mm wall*				
75 mm diameter/2-14.2 mm wall*		25 mm	13 -19 mm Kaiflex ST insulation	
90 mm diameter/2.4-14.2 mm wall*		Graft Mineral	31 ilisulation	EI 60
100 mm diameter/2.7-14.2 mm wall*		Fibre BIO		
115 mm diameter/3.1-14.2 mm wall*				
140 mm diameter/3.8-14.2 mm wall*				
165 mm diameter/ 4.5-14.2 mm   wall*				

<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes


### Pipe diameter vs Wall thickness



Services	Sealant	Backing	Insulation	Classification	
Copper pipe	depth				
12 mm diameter/1 mm wall		25 mm	9 mm Kaiflex ST insulation	E 240 C/C, EI 180 C/C	
12-54 mm diameter/1-1.2 mm wall	25 mm	Graft Mineral	9-13 mm Kaiflex ST insulation	E 180, EI 120 C/C	
12-54 mm diameter/1-1.2 mm wall	Fibre BIO		13-25 mm Kaiflex ST insulation	E 90 C/C, EI 60 C/C	
Gerberit Mepla MLC (PE-Xb/Aluminium	n/PE-HD pipe	e)*			
16 mm diameter/2.25 mm wall			9 mm Kaiflex ST insulation	EI 180 C/C	
16 mm diameter/2.25 mm wall					
20 mm diameter/2.5 mm wall	25 mm				
26 mm diameter/3 mm wall					
32 mm diameter/3 mm wall			9-13 mm Kaiflex ST	E 120 C/C, EI 60 C/C	
40 mm diameter/3.5 mm wall			insulation	L 120 C/C, LI 00 C/C	
50 mm diameter/4 mm wall					
63 mm diameter/4.5 mm wall		25 mm Graft Mineral Fibre BIO			
75 mm diameter/4.7 mm wall					
16 mm diameter/2.25 mm wall					
20 mm diameter/2.5 mm wall					
26 mm diameter/3 mm wall					
32 mm diameter/3 mm wall			13-25 mm Kaiflex	EI 60 C/C	
40 mm diameter/3.5 mm wall			ST insulation	E1 60 C/C	
50 mm diameter/4 mm wall					
63 mm diameter/4.5 mm wall					
75 mm diameter/4.7 mm wall					

#### A.3.7 Double side penetration seal with metallic pipes


**Penetration Seal:** 1000 mm (min.) LI (Local Interrupted) or CI (Continuous Interrupted) insulated metallic pipes (single) fitted central within the aperture, with 15 mm deep Graft FR Acrylic to both sides of the floor (or at any position between), backed with 20 or 30 mm deep 40 kg/m<sup>3</sup> stone wool insulation\*.




#### A.3.7.1

Services	Seal size	Insulation	Classification
Mild or stainless steel pipe			
40 mm diameter/1-14.2 mm wall		20 mm Stone wool	EI 240 C/U
40 mm diameter/1-14.2 mm wall*		insulation 80 kg/m <sup>3</sup>	
50 mm diameter/1.2-14.2 mm wall*			
60 mm diameter/1.4-14.2 mm wall*			
75 mm diameter/1.7-14.2 mm wall*			
90 mm diameter/2-14.2 mm wall*	300 x 300 mm or 100 x 1000 mm	30 mm Stone wool insulation 80 kg/m <sup>3</sup>	E 240, EI 120 C/U
100 mm diameter/2.2-14.2 mm wall*			
115 mm diameter/2.5-14.2 mm wall*			
140 mm diameter/3-14.2 mm wall*			
165 mm diameter/3.5-14.2 mm wall*			
180 mm diameter/3.8-14.2 mm wall*			
200 mm diameter/4.2-14.2 mm wall*			
219 mm diameter/4.5-14.2 mm wall*			

<sup>\*</sup> Typical pipe diameters shown, see below graph for intermediate sizes







#### A.3.8 Double side penetration seal with plastic pipes

**Penetration Seal:** Combustible pipes sealed with Graft FR Acrylic, to both sides of the floor backed with Stonewool ( $35 \text{kg/m}^3$  density), 25 mm deep. Minimum separation between penetration seals of 30 mm ( $a_2$ ) and seal size/annular space of 10-30 mm ( $a_1$ ).


#### Construction details:



#### **Configuration 1**



#### Configuration 2



#### Key

- 1 Supporting construction
- a<sub>1</sub> Pipe / edge of seal separation (annular space)
- a<sub>2</sub> Separation between penetration seals

#### A.3.8.1

Services	Sealant depth	Backing	Aperture Ø	Classification
PP pipe according to EN 1451-1 40 mm Ø/3 mm wall	-	25 mm Graft Mineral Fibre BIO	65 mm	EI 120 U/C, EI 120 C/C
75 mm Ø/2.8 mm wall			115 mm	EI 180 U/C, EI 180 C/C
PE (PE-HD) pipe according to EN 1519-1, EN 12201-2 and EN 12666-1, ABS according to EN 1455-1 and pipes made from SAN+PVC according to EN 1565-1 40 mm Ø/4 mm wall	25 mm	25 mm stone wool 140 kg/m <sup>3</sup>	65 mm	EI 240 U/C, EI 240 C/C
PVC-U pipes according to EN 1329-1, EN 1453-1 or EN 1452- 1, PVC-C according to EN 1566-1 up to 40 mm Ø and 1.6-3.4 mm wall		25 mm stone wool 35 kg/m <sup>3</sup>	Up to 100 mm	EI 240 U/C, C/C