



6	1	Warmwasseranschluss_8mm_G1-2 200°C	Dosing-connector_8mm_G1-2 200°C	L30046
5	1	Schlauch d 6/ 4mm PTFE	Dosing tube d 6/ 4mm PTFE	619643
4	1	Suct.ass. w.fl.sw.-2stg.sz.l 6x4 PPE	Suction assembly 6 x 4mm PPE	619692
3	1	Dos.beh. 60L ohne Logo PE-natur	Chem.tank 60L w.o. logo PE-nature	619619
1	1	BT4B1602PVT2000UA000000	Dosing pump BT4B1602PVT2000UA000000	773184
Item	Qty	Bezeichnung	Description	IFS Code

Scope of application	Welding Tol.	toler. Deviati.	Surface	Scale: 1:6	Weight: xy kg
1036992	DIN ISO DIN ISO	DIN ISO DIN ISO	DIN ISO DIN ISO	Material: SS PTFE	
08			Name	Boiler Water Dosing Station 16bar	
07		Drawn 08.12.2010	fuchs-Lawe		
06		Checked 08.12.2010	Bonke		
05					
04					
03		ProMaqua GmbH Maaßstraße 32/1 D 69123 Heidelberg		Code -767922	
02					
01		Origin: Unitor_Boiler_Water_Station_16bar.dff		Sheet 1/1	
Rev	Date	Name	Modification		