



6	1	Warmwasseranschluss_8mm_G1-2 200°C	Dosing-connector_8mm_G1-2 200°C	L30046
5	1	Schlauch d 8/ 4mm PTFE	Dosing tube d 6/ 4mm PTFE	619643
4	1	Suct.ass. w.fl.sw.-2stg.sz.l 6x4 PPE	Suction assembly 2m 6x4 PPE	619692
2	1	Dos.beh. 60l ohne Logo PE-natur	Chemical tank 60lit	619619
1	1	BT5B2504NPT2000UA000000	Dosing pump BT5B2504NPT2	773192
Item	Qty	Bezeichnung	Description	IFS No.

Scope of application	Welding Tol.	toler. Deviat.	Surface	Scale: 1:6	Weight: xy kg
1036993	DIN ISO DIN ISO	DIN ISO DIN ISO	DIN ISO DIN ISO	Material: SS PTFE	
08			Name	Boiler Water Dosing Station 25bar	
07		Drawn 08.12.2010	fuchs-Laue		
06		Checked 08.12.2010	Bonke		
05					
04					
03	ProMaqua GmbH Maaßstraße 32/1 D 69123 Heidelberg			Code 767923	
02					
01				Sheet 1/1	
Rev	Date	Name	Modification	Origin:	Unitor_Boiler_Water_Station_25bar.dft