

BACTERIA COUNT TEST – 10 pck

Order no: 568568


1. 

Insert the Dip Slide into the cooling water for 10 sec.
2. 

Without touching the gel put the Dip Slide into the tube
3. 

Keep the Dip Slide warm (min. 37° C) for 48 h.

4.



If bacteria is present in the Cooling Water , red spots will show on the Dip Slide Gel

Note: Limited shelf life for this product